# Security Monitoring and Network Management for the Power Control Network

Sugwon Hong, Jae-Myeong Lee, Mustafa Altaha, and Muhammad Aslam Department of Computer Engineering, Myongji University, Yongin, R. of Korea Email: {swhong; mustafaraed}@mju.ac.kr; {ljm9317kr; aslammju}@gmail.com

Abstract-Security monitoring is a viable solution to enhance the security capability in the current power control Supervisory Control and Data Acquisition (SCADA) system, more broadly Industrial Control System (ICS), since the intrusion detection system as a main tool for monitoring can be easily deployed without any change of SCADA configuration. We explain how to design the SCADA domain-specific network security monitoring system, reflecting semantics of the target SCADA network. However, the attack vectors of the recent attacks to the SCADA/ICS systems are the vulnerabilities of the software underlying the host systems. In this respect, we need security monitoring running on host systems which can provide process and memory protection. Furthermore, network and system management (NMS), which incorporates the traditional network management into the power control system, can not only help to manage and maintain the IT/OT (information technology and operational technology) systems in a unified way, but also enhance the security capability of the SCADA system with collaboration with network and host security monitoring.

*Index Terms*—Cyber security, IDS, network management, power control network, SCADA, security monitoring

## I. INTRODUCTION

Realizing the importance of cyber security of the Supervisory Control and Data Acquisition (SCADA) network which lies in the core of the power control system, a plethora of works have been published to address this issue by international standard bodies, government organizations, utilities, vendors, and academic researchers. These cyber security-related documents published mainly by international standard bodies and government organizations are classified by two criteria. One is the degree of technological details by which the documents can fall under management-oriented or technology-oriented categories. The other is the target or domain to which the documents are intended. All the security measures proposed and adopted in those documents eventually come under one of three security strategies: network separation, communication message security, and security monitoring [1].

Even though complete physical separation is not possible in the current SCADA network, logical network separation, which divides the network into different domains depending on criticality or functionality or any other purposes, is an effective strategy to prevent unwarranted entries into the network. Each domain constitutes a virtually separated network which is only connected to other domains via dedicated entry points. only on which all information flows are exchanged and strict security policing is enforced. The primary goal is that when attackers try to penetrate deeper networks, it can reduce the probability of attack success, i.e. attacks are as isolated into a penetrated network domain as possible, mitigating attack impacts. The concept to separate one network into several segmented zones or domains is nothing new in the network design of the Information Technology (IT) world. Firewall and Intrusion Prevention System (IPS) are common equipment used for this purpose, and virtual private local area network (VPN) is a common network design technique used for deploying logically separate networks. The network separation, the strategy of which is often called 'defense-in-depth', is the go-to strategy that is being implemented in the current SCADA/ICS system, and it will continue to act as a primary defense strategy [2], [3].

Communication message security in the power control system is aimed at providing the integrity, authentication, and/or confidentiality of messages exchanged between devices in the SCADA system, based on digital signature, keyed-hash message authentication code (HMAC), crypto algorithms, and security protocols such as Transport Layer Security (TLS). The International Electrotechnical Commission (IEC) standards [4]-[7] addresses this issue, specifying security measures to provide the integrity, authentication, and/or confidentiality of communication messages defined in the IEC 61850 standards, which are officially utilized for substation automation systems.

However, the major challenge of this strategy lies in implementation. Embedded devices in substations have limited computing resources and can devote only a part of their resources for security processing. In addition to implementation, migration is another daunting challenge since installing security functions into legacy devices

Manuscript received December 1, 2019; revised January 12, 2020; accepted March 10, 2020.

Corresponding author: Sugwon Hong (email: swhong@mju.ac.kr).

This work was supported by "Human Resources Program in Energy Technology" of the Korea Institute of Energy Technology Evaluation and Planning (KETEP), granted financial resource from the Ministry of Trade, Industry & Energy, Republic of Korea. (No. 20174030201790) and this research was also supported by Korea Electric Power Corporation. (Grant number: R18XA01).

overnight is not possible. Replacement or even retrofitting process will be difficult and time-consuming because SCADA systems should be in 24/7 operation. Considering implementation and migration challenges, it is hard to expect to adapt the communication message strategy to the SCADA system in the foreseeable future.

Security monitoring is also an integral part of security strategies in the traditional networks. While network separation is aimed to prevent unauthorized access into the SCADA system, security monitoring intends to detect and reports any illegitimate behavior inside the SCADA system. In reality, network separation cannot guarantee complete prevention of illegal access, but only can decrease the possibility of unauthorized access and mitigate any disruptive incidents by illegal operations. For this reason, security monitoring is considered to be an indispensable part of security strategies.

Compared to typical IT systems, the SCADA systems have predictable patterns of traffic flow between fixed network nodes. This simplicity renders monitoring solution more attractive in the SCADA system. Furthermore, the communication in the SCADA system mostly rely on the standard protocols such as IEC 61850, DNP3 (distributed network protocol 3), and Modbus, which correspond to the application layer protocols above the TCP/IP stack. This uniformity makes easy to derive rules from the protocols, which can be used to decide which behaviors are normal or not in the network. Moreover, security monitoring can be easily adopted to the current SCADA network without any significant change of system architecture and components. In this sense, security monitoring strategy can provide much room for enhancing security capability in the current system without any hassle.

In this paper we will explain how to design network security monitoring which is reflecting the semantics of the underlying SCADA systems based on the analysis of the current works. We also point out the limitation of the network security monitoring approach, considering the current cyber-attacks against the SCADA/ICS systems. And we explain the necessity of host-level security monitoring.

Network management is an essential tool to monitor and control a network system in a comprehensive way. However, the current network management system is only focused on network components, consequently causing IT and OT (operational technology) management to be separated. In this respect, network and system management (NMS) will help to realize the integration of IT and OT operations. Another benefit of monitoring based on network management is that it can provide the possibility to upgrade the capability of security in SCADA systems.

## II. NETWORK SECURITY MONITORING

Network security monitoring is to do the collection, analysis, and escalation of indications and warnings to detect and respond to intrusions. Security monitoring is a way of finding intruders on the network and do something about them before they damage the system [8]. In a nutshell, security monitoring is involved in detecting and reporting any illegal behaviors in the system, consequently providing the necessary high-level of security and reliability in the SCADA system.

The intrusion detection system (IDS) is a main tool to do security monitoring. The techniques of IDS, in which we are interested for the SCADA system, is the anomalybased detection. The anomaly detection is the process to determine which observed events are to be identified as abnormal because it has significant deviation from normal behavior which is called 'profile.' As always, the difficult part is how to decide or derive profiles which reflect all semantics of the system. Thus, the main task to do security monitoring is to design domain-specific IDS which is aware of the target domain semantics. Here, we classify four kinds of information to derive profiles for SCADA-aware IDS: network flows, application protocols, process features, and data features for self-learning.

Fig. 1 shows the framework of the anomaly-based intrusion detection. In this framework, the learning box to derive profiles is part and parcel of the whole procedure. Analyzing inputs to the learning box, we derive profiles or normal behavior.



Fig. 1. Framework of intrusion detection system (IDS).

# A. Flow-Aware Monitoring

The first input to the learning box to be considered is the information about network traffic flows in the target system. As the paper [9] well pointed out, the SCADA networks have very predictable patterns compared to IT networks. In the IT network, it is not possible to completely predict a list of allowable communication paths. A large portion of the traffic occurring in the IT network is involved in human actions, leading to dynamic traffic patterns. On the contrary, the SCADA network configuration is stable and has the fixed IP addressing schemes. Unless there is any abrupt change in the system configuration, intentional or unintentional, communication paths are deterministic since data exchanges take place between fixed nodes such as control servers, intelligent electron device (IED), programmable logic controller (PLC), remote terminal unit (RTU), and other field devices, which are mostly machine-to-machine communication.

Considering the current substation automation system (SAS) is running on the TCP/IP stack and Ethernet-based local area networks (LANs), the flow can be defined by the 3 address tuples of source and destination stations: (media access control address, IP address, TCP/UDP

port). Then, we can specify a list of allowable flows in the network, which is often called a whitelist. This list can be preconfigured based on the knowledge of legitimate nodes and communication in the network, and/or dynamically managed based on the result of monitoring traffic by switches in the network. The network flow-aware anomaly detection approach are elaborated in the papers [9]-[12].

## B. Protocol-Aware Monitoring

These days, the SCADA networks in the power control system are operating based on the standard communication protocols such as IEC 61850, IEC 60870-5-104, DNP3.0, and Modbus. All the measured data, state information, and on/off command are delivered as the application protocol data unit (APDU) encapsulated in IP packets. The semantics of each fields in the APDU can be used to verify the validity of the incoming packets, and detect any anomalous communication. Furthermore, any correlated rules between different fields of the same packet or between the fields of subsequent packets are also utilized as effective criteria to decide whether incoming packets obey the logic of the application protocols.

For example, if the sequence number field exits in the header, the sequence numbers of all packets should be in order, and the following packet's number should be incremented by one. Time stamp field is also useful to check the correctness of a series of arriving packets. In this way, the extracted APDU information of incoming packets is compared with profiles by simple matching or sometimes checking rules of a single packet or between the sequences of packets.

In practice, the rules that could be derived from the information of APDU are much more complex than the simple examples explained above. The deeper we go into the inside of APDU, the more detailed and reliable rules we can extract. This Deep Packet Inspection (DPI) is currently being touted as one direction of security monitoring approach in the SCADA system.

The papers [13]-[20] derive the profile regarding IEC 61850 protocols. The papers [21], [22] propose IDS based on DNP3.0 and IEC 60870-5-104 which is a variation of DNP3.0. The paper [23] proposes IDS relating to Modbus protocol, and the paper [24] proposes the framework to generate dynamic rules for multiprotocols. The protocol-aware anomaly detection approach can be integrated with the flow-aware method together, since the SCADA-specific application protocols are running over the TCP/IP stacks. This approach is also called the rule-based, model-based, or specification-based anomaly detection in other literatures

## C. Process-Aware Monitoing

The effectiveness of anomaly detection can be increased as we can derive profiles which are more aware of semantics of the target SCADA system. If we can extract normal/abnormal features from the changes of states at the process level, we can enhance the performance of anomaly detection capability. The papers [25]-[30] propose and explain this approach, which we call the process-aware anomaly detection approach. This deep process-level inspection method, compared to the deep packet inspection, tries to capture useful features from the relation of the process-relevant parameters: data semantics of sensors and actuators, logics of commands, and dynamics of process operations.

The framework of this method can be generalized as in Fig. 2. The commands issued by control servers intend to do some specific operations and generate new state at the process-level operation. Then, IDS compares new state with the predicted state which is the intended state and acts as a normal state. If deviation from the predicted state surpasses a defined threshold, the state is interpreted as abnormal. In this way, when suspicious or erroneous commands are detected, the detection system generates alert signals in order to avoid the process reaching insecure or unsafe states.

Naturally, this approach can be combined with the protocol-aware monitoring under the banner of the deep packet inspection [17], [19].



Fig. 2. Process-aware IDS framework.

# D. Self-Learning-Based Monitoring

In recent years, many researchers have begun to focus on constructing SCADA-IDSs using machine learning and deep learning methods. Machine learning-based IDSs can achieve satisfactory detection levels when sufficient training data is available, and machine learning models have sufficient generalizability to detect attack variants and novel attacks. Compared with traditional machine learning methods, deep learning methods are better at dealing with a large volume of data. Moreover, deep learning methods can automatically learn feature representations from raw data and then output results.

While considerable works on machine learning-based SCADA-IDSs have been done so far, few works have been carried out for deep learning-based IDSs focusing on the SCADA systems [31]-[37]. Moreover, fewer works have been reported on the power SCADA systems [33], [35], while others are focusing on the different SCADA domains such as gas pipeline networks [31], [36], water treatment systems [34], [37], and heating control system [32].

The framework of the deep learning-based IDS is shown in Fig. 3. First and foremost, meaningful design of deep learning detection model requires significant understanding of domain knowledge and acquisition of proper datasets. In this sense, the data feature extraction is the most important step to develop successful detection models. From raw network traffic, we should derive the feature vector at time t,  $X_t = (x_0, x_1, \dots, x_n, \text{label})$  to train and test a deep learning model, consequently constructing the detection model which is corresponding to the profile of IDS. The *label* in the feature vector signifies the types of attacks, which might be a binary value or multi-class values. The input features,  $(x_0, x_1, \dots, x_n)$  should reflect the semantics of the SCADA domains. So far, all the works are using the data field information of the application protocol data units (PDU) of the SCADA communication protocols such as Modbus [31], [32], [34] and DNP3.0 [33], [35], along with the TCP/IP header information.



Fig. 3. Deep learning-based IDS framework.

Together with the input data features, the deep learning models will affect the effectiveness of the detection model. The deep learning models to be used in the papers are varied: Long short term memory (LSTM) [31], [34]; artificial neural network (ANN) [32]; convolution neural network (CNN) [33], [36]; and recurrent neural network (RNN) [35], [37].

Ironically, automatic learning capability of the deep learning approaches is the merits, and also demerits at the same time. Contrary to the other monitoring methods, the profiles of which we can understand and control, the deep learning detection model, i.e. the profiles, is opaque to us, which means we cannot understand and control the detection logics of the profiles.

Machine and deep learning provides significant benefits, since it is expected to offer capability of agile updating in defense to respond new variants of attacks. However, model construction requires significant understanding of the problem being addressed, which involves analyzing the data collected to extract 'features' that are used to learn detection logics. The challenge of deep learning-based IDS lies in proper usage of data features for training and testing to reflect as much of semantics of the SCADA system as possible, and reasonable validation to verify its usefulness of defense against attack variants.

# III. EVALUATION

The attack model or scenario in the power system can be summarized into two steps: first, an attacker penetrates any vulnerable stations in the SCADA network, and finally an attacker generates maliciously coded commands to the field devices and causes the power system into insecure or unsafe states. The possible attacks, on which most anomaly detection systems set their sights, are data injection, data modification, data interruption, and denial of service (DoS) attacks among others [38], because these attacks are directly related to compromise field devices, consequently causing malfunction in the power operation.

Then, the question is whether the network security monitoring explained in the previous section can detect these attacks. The answer, unfortunately, is not optimistic, considering the substance of the recent sophisticated attacks against the SCADA/ICS systems [39]-[49].

One of main purposes of anomaly detection is to check the integrity and authenticity of data exchanged, i.e. whether they comply with the underlying SCADA protocols and accompanying rules in the system. In the real systems, however, there are other types of information or messages that are exchanged for configuration and operation related to various software, especially operating system (OS). The recent attacks, which targeted the SCADA/ICS systems, hijack or take control of host stations, control servers and eventually device controllers, once they penetrate the networks in one way or another. Their attack vectors are vulnerabilities of the software underlying the host systems. In this respect, we need to pay attention to the supply chain management and precaution for managing and/or outsourcing servers.

The network IDS, which is currently proposed in the context of the SCADA/ICS systems, intends to detect anomaly behavior based on traffic patterns or contextual mismatch of message contents which are specified in the standard protocols such as Modbus, DNP3.0 and IEC61850. However, the real attacks do not take place via the standardized and defined communication messages. Rather, the attacks were accomplished by way of taking over central servers and local device controllers [50].

As shown in the Stuxnet [47]-[49], the attack was realized by injecting malicious codes – dynamic link library (DLL) files in this case- into legitimate process memory and executing the malicious codes in the context of a legitimate process. Once a malicious code is injected into the target process, it has full access to the process memory and can manipulate code and data blocks of PLC, and eventually causes malfunction of field devices. For this reason, the deep packet inspection of the protocolbased IDS, which checks the authenticity and integrity of the messages exchanged between control servers and local device controllers, can hardly detect these kinds of attacks.

In this respect, the process-aware monitoring is considered to be more reasonable and effective approach, since it can consider the semantics of process-level operations without direct checking of the authenticity and integrity of communication messages. This kind of monitoring can be used to support a central IDS, locating at the LAN of the process domain.

If we want to find any security solutions on top of vendor-dependent platforms, we need to take special attention to the attack vectors which have been revealed in the recent attacks. From all incidents, we can notice that every known malware attack on the SCADA system exploits weaknesses of host system environment. Therefore, it is important to prepare measures on this kind of attacks.

## IV. HOST SECURITY MONITORING

In this section, we focus on the most commonly used attack method such as Code Injection, more specifically DLL Injection in the recent SCADA/ICS attacks. In order to execute all the programs, all executable codes as well as external libraries such as DLL files, which are referred to by the executable codes, should be loaded into process memory. In the same way malicious codes can be loaded into the memory, which is often called the code injection technique. By way of the code injection, attackers can execute malicious codes in the name of legitimate processes, access the code memory and data memory of the main processes, and also hide themselves from monitoring imposed by the internal security policies of security solutions. The code injection, by which attackers inject their intended codes, can take a form of directly writing executable codes or shellcode into memory or of loading their DLL files into memory.

For the former case, they utilize the memory management system calls. First, they assign necessary memory space by the memory allocation system calls, and load the executable binary codes into memory space by the memory writing system calls. To execute these loaded codes, they often create new threads. In the case of loading DLL which is also called 'DLL injection', once the malicious DLL files are loaded into the target process, the process refers to these files on executing without any extra manipulation. Attackers utilize invoking the loader system calls by thread generation, or windows hooks, or DLL swapping. In general, the DLL injection is more utilized for its convenience [51].

Once a code is injected onto the target process memory, it has full access to the process memory and can modify its components. Manipulating the process memory components enables attackers to modify system functions (executable codes) or to change the function addresses such as entries in the Import Address Table (IAT). This technique is called as 'hooking'. In this way attackers can force their intended codes to be executed instead of original legitimate codes.

In order to detect and prevent such attacks, we need security measures to detect any process manipulation which is involved in memory range protection, file paths, and file handling. To prevent the attack of the executable code injection, we should inspect whether the process memory is assigned by legitimate executable codes or loading legal DLL files, or allocated by external system calls, which can be examined by referring to memory information enquiry functions provided by the OS. For the case of the DLL injection, we can utilize the method to find out where the codes to invoke the DLL load calls are located [52].

## V. NETWORK MANAGEMENT

## A. IT/OT Convergence

Traditionally, network management is an indispensable tool to manage complex IT network systems. Network

management enables a human manager to have a big picture of complex systems by monitoring the status and operation of all network components in real-time. So, this leads to obtain up-to-date information about system components at the right time.

Currently SCADA operation management and IT network management are separated. SCADA servers or Energy Management System (EMS) collect operation information from Intelligent Electronic Devices (IED) over the IT network. Then the SCADA operation manager takes necessary actions based on this operation information about the SCADA system. On the other hand, the IT network manager collects information about network component such as switches, routers, and transmission equipment, which consists of the IT network overlaying the SCADA system. The SCADA operation manager is blind to the IT network, and at the same time the IT network manager is also unaware of the SCADA operating system components. For example, when SCADA operation managers detect an anomalous state, they could not decide whether it is caused by the IT network or an IED failure [53].

To expand the concept of network management to the SCADA system can enhance the capability of monitoring IT/OT system in an integrated way. The agent residing in the SCADA system component, mainly IED, collects information regarding physical access, communication security. SCADA protocols, clock, and environment, so that the IT/OT network manager can have the integrated view of the SCADA operating components as well as IT communication components. For this purpose, we need to expand the network and system management (NSM) data objects to reflect what information is needed to manage the SCADA system reliably. The abstract NSM data objects can then be mapped to any appropriate protocol. At present, some of SCADA system device vendors define private Management Information Bases (MIB) and try to utilize them for monitoring SCADA operations. In order to provide interoperability and a unified approach to NSM, IEC defines the standard MIBs for the substation automation devices [54].

#### B. Integrated Security Monitoring



Fig. 4. Substation automation system with NSM and IDS.

NSM typically have two functional aspects: management and monitoring. NSM provides the

integrated view of the IT/OT system and resolve detected problems and facilitate maintenance. To acquire information that is related to the operational aspects of the SCADA infrastructure provides the capability of NSM monitoring. Not only can such information be utilized for system operation optimization, it can also be applied to security threat detection, which is the main role of IDS. The question is how an NSM manager interacts with IDS for this purpose. One possible interaction scenario and configuration is shown in Fig. 4. In this figure, IDS is placed as a standalone device and collect necessary information for its own purpose. And IDS will send results of its actions, so NSM share this report to make any critical security decision.



Fig. 5. Framework of integrated security monitoring.

One advantage of NSM monitoring is that we can obtain deep-level data of field devices along with network traffic data. Utilization of this deep-level data can enhance the capability of security monitoring together with network-aware and host-aware IDSs. Fig. 5 shows the framework of a way of integrating security monitoring, combining all functions of three components: network-based IDS, host-based-IDS, and NSM monitoring.

The current IEC 62351-7 MIBs do not contain all the information that is necessary to implement the IDS functions explained in section II [54]. The detection functions based on NSM MIBs are limited to detect physical access and resource exhaustion with respect to IED. Applying NSM to the SCADA system will take time, while the deployment of IDS can be deployed anytime when it is necessary and ready without any impact on the SCADA system configuration.

## VI. CONCLUSION AND FUTURE DIRECTION

Network separation is currently the dominant security strategy that the SCADA systems rely on. Security monitoring is a viable solution to enhance the security capability in the SCADA system, considering that the deployment of intrusion detection systems (IDS) is applied without any change of current SCADA system configuration. The main challenge is how to design SCADA domain-specific IDS which reflects the semantics of the SCADA system. The profiles of SCADA-friendly IDS can be derived based on network flows, application protocols, process-aware features, and deep learning techniques.

However, considering the recent attacks against SCADA/ICS systems, the network-based security monitoring does not provide sufficient measures to detect and prevent these sophisticated attacks. For this reason, we need to derive profiles which are more aware of semantics of the target SCADA system. In this sense, the process-aware IDS is more appropriate to defend sophisticated attacks which are eventually targeting field devices.

With the success of deep learning techniques in other areas, anomaly intrusion detection system is emerging as a promising application area of deep learning. However, deep learning-based IDS for the SCADA systems is still at a fledgling stage. Constructing deep learning models requires a significant understanding of the domain knowledge. Relating to SCADA security, the knowledge means to understand attack patterns, operating mechanisms, and process (or field) networks, which have different characteristic and semantics from the typical IT systems. Creating successful models also requires deep expertise in SCADA data features which are used for learning. Learning requires to collect massive amounts of real-life information and engineer it into useful formats.

The nature of the recent sophisticated attacks against SCACA/ICS systems is to exploit software vulnerability, performing process manipulation by injecting malicious codes into legitimate process memory and executing the malicious codes in the context of a legitimate process. Thus, we need security monitoring running on host systems which can provide process and memory protection. These measures can provide a holistic security monitoring strategy for the power control system.

Recently, the IT network management technique is applied to the OT system, providing a way of IT/OT management integration. However, the current IT/OT management is focusing on only monitoring OT system components in order to facilitate maintenance functions. However, cooperating with network-based and hostbased IDS, the network and system management (NSM) can enhance the capability of security monitoring.

## CONFLICT OF INTEREST

The authors declare no conflict of interest.

## AUTHOR CONTRIBUTIONS

Sugwon Hong researched, designed, and wrote the paper. Jae-Myeong Lee did the work on the part of host security monitoring, and Mustafa Altaha did literature survey and analysis on deep learning-based IDS. And Muhammad Aslam gave valuable advices and comments to improve the paper.

#### REFERENCES

[1] S. Hong, "Cyber security strategies and their implications for substation automation systems," *Int'l J. of Smart Grid and Clean Energy*, vol. 8, no. 6, pp. 747-756, November 2019.

- [2] Recommended Practice: Improving Industrial Control System Cybersecurity with Defense-in-Depth Strategies, DHS ICS-CERT. September 2016.
- [3] Guide to Industrial Control Systems (ICS) Security, NIST SP 800-82 Rev.2, May 2015.
- [4] Power Systems Management and Associated Information Exchange - Data and Communications Security - Part 3: Communication Network and System Security – Profiles Including TCP/IP, IEC TC57 WG15, IEC 62351-3, May 2018.
- [5] Power Systems Management and Associated Information Exchange - Data and communications Security - Part 4: Profiles Including MMS, IEC TC57 WG15, IEC 62351-4, November 2018.
- [6] Power Systems Management and Associated Information Exchange - Data and Communications Security - Part 5: Security for IEC 60870-5 and Derivatives, IEC TC57 WG15, IEC 61850-5, 2013.
- [7] Power Systems Management and Associated Information Exchange - Data and Communications Security - Part 6: Security for IEC 61850, IEC TC57 WG15, IEC 62351-6, 2007.
- [8] R. Bejtlich. The Practice of Network Security Monitoring: Understanding Incident Detection and Response, No Starch Press, 2013.
- [9] A. Lemay, J. Rochon, and J. Fernandez, "A practical flow white list approach for SCADA systems," presented at the 4th International Symposium for ICS & SCADA Cyber Security Research, 2016.
- [10] G. K. Ndonda and R. Sadre, "A two-level intrusion detection system for industrial control system networks using P4," presented at ICS & SCADA, 2018.
- [11] R. Udd, M. Asplund, S. Nadjm-Tehrani, M. Kazemtabrizi, and M. Ekstedt, "Exploiting bro for intrusion detection in a SCADA system," presented at CPSS'16, June 2016.
- [12] R. Barbosa, "Anomaly detection in SCADA systems, a network based approach," Ph.D. dissertation, University of Twente, April 2014.
- [13] M. Ko and M. Jenkner, "Cybersecurity defense system for distributed communication network in IEC-61850 power substations," *Cigre De Colloquium*, June 2019.
- [14] J. Hong and C. C. Liu, "Intelligent electronic devices with collaborative intrusion detection systems," *IEEE Tran. on Smart Grid*, vol. 10, no.1, pp. 271-281, January 2019.
- [15] M. Kabir-Querrec, "Cyber security of the smart grid control systems: Intrusion detection in IEC 61850 communication networks," Ph.D. dissertation, University Grenoble, 2017.
- [16] M. T. A. Rashid, S. Yussof, and Y. Yusoff, "Trust system architecture for securing GOOSE communication in IEC 61850 substation network," *International Journal of Security and its Applications*, vol. 10, no. 4, pp. 289-302, 2016.
- [17] Y. Yang, H. Q. Xu, L. Gao, Y. B. Yuan, and K. McLaughlin, "Multidimensional intrusion detection system for IEC 61850 based SCADA networks," *IEEE Trans. on Power Delivery*, vol. 32, no. 2, pp. 1068-1077, April 2017.
- [18] J. Hong and C. C. Liu, "Integrated anomaly detection for cyber security of the substation," *IEEE Trans. on Smart Grid*, vol. 5, no. 4, pp. 1643-1653, July 2014.
- [19] Y. Yang, K. McLaughlin, S. Sezer, T. Littler, E. G. Im, B. Pranggono, and H. F. Wang, "Multiattribute SCADA-specific intrusion detection system for power networks," *IEEE Trans. on Power Delivery*, vol. 29, no. 3, pp. 1092-1102, June 2014.
- [20] Y. Yang, K. McLaughlin, L. Gao, S. Sezer, Y. Yuan, and Y. Gong, "Intrusion detection system for IEC 61850 based Smart Substations," presented at IEC Power and Energy Society General Meeting, 2016.
- [21] H. Lin, A. Slagell, C. D. Martina, Z. Kalbarczyk, and R. K. Lyer, "Adapting bro into SCADA: Building a specification-based intrusion detection system for the DNP3 protocol," presented at CSIIRW '12, October 2012.
- [22] Y. Yang, K. McLaughlin, T. Littler, S. Sezer, B. Pranggono, and H. F. Wang, "Intrusion detection system for IEC 60870-5-104

based SCADA networks," *IEEE PES General Meeting*, Vancouver, July 2013.

- [23] S. Cheung, R. Dutertre, M. Fong, U. Lindqvist, and K. Skinner, A. Valdes, "Using model-based intrusion detection for SCADA networks," presented at the SCADA Security Scientific Symposium, January 2007.
- [24] J. Nivethan and M. Papa, "Dynamic rule generation for SCADA intrusion detection," presented at IEEE Symposium on Technologies for Homeland Security, May 2016.
- [25] J. J. Chromik, A. Memke, and B. Haverkort, "Bro in SCADA: Dynamic intrusion detection polices based on a system model," presented at ICS & SCADA, 2018.
- [26] H. Lin, A. Slagell, Z. T. Kalbarczyk, P. W. Sauer, and R. K. Iyer, "Runtime semantic security analysis to detect and mitigate control-related attacks in power grids," *IEEE Trans. on Smart Grid*, vol. 9, no. 1, pp. 163-178, January 2018.
- [27] J. Nivethan and M. Papa, "A SCADA intrusion detection framework that incorporates process semantics," presented at CISRC, 2016.
- [28] J. J. Chromik, A. Remke, and B. R. Haverkort, "What's under the hood? Improving SCADA security with process awareness," presented at Joint Workshop on Cyber-Physical Security and Resilience in Smart Grids (CPSR-SG), 2016.
- [29] H. Janicke, A. Nicholson, S. Webber, and A. Cau, "Runtimemonitoring for industrial control systems," *Electronics*, vol. 4, pp 995-1017, 2015.
- [30] D. Hadziosmanovic, R. Sommer, E. Zambon, and P. H. Hartel, "Through the eye of the PLC: Semantic Security Monitoring for industrial processes," presented at the 30th Annual Computer Security Applications Conference (ACSAC), New Orleans, December 2014, pp. 126-135.
- [31] R. L. Perez, F. Adamsky, R. Soua, and T. Engel, "Forget the myth of the air gap: Machine learning for reliable intrusion detection in SCADA systems," *EAI Endorsed Trans. on Security and Safety*, 2019.
- [32] A. Hijazi, E. A. Safadi, and J. M. Flaus, "A deep learning approach for intrusion detection system in industry network," presented at the 1st Int'l Conference on Big Data and Cybersecurity Intelligence, Beirut, Lebanon, 2019.
- [33] H. Yang, L. Cheng, and M. D. Chuah, "Deep-learning-based network intrusion detection for SCADA systems," presented at IEEE Conf. on Communication and Network Security (CNS): Workshops: CPS Sec: Internation Workshop on Cyber-Physical Systems Security, 2019.
- [34] J. Gao, L. Gan, F. Buschendorf, L. Zhang, H. Liu, P. Li, X. Dong, and T. Lu, "Omni SCADA intrusion detection using deep learning algorithms," arXiv, Aug. 2019.
- [35] S. Kwon, H. Yoo, and T. Shon, "RNN-based anomaly detection in DNP3 Transport layer," presented at IEEE Int'l Conf. on Communications, Control, and Computing Technologies for Smart Grids (SmartGridComm), 2019.
- [36] J. Liu, L. Yin, Y. Hu, S. Lv, and L. Sun, "A novel intrusion detection algorithm for industrial control systems based on CNN and process state transition," presented at IEEE 37th Int'l Performance, Computing and Communications, 2018.
- [37] J. Goh, S. Adepu, M. Tan, and L. X. Shan, "Anomaly detection in cyber physical systems using recurrent neural networks," presented at IEEE 18th Intl Symposium on High Assurance Systems Engineering, 2017.
- [38] A. Elgargouri and M. Elmusrati, "Analysis of cyber-attacks on IEC 61850 networks," presented at IEEE 11th Int'l Conf. on Application of Information and Communication Technologies, Sept 2017.
- [39] J. Slowik. (2020). Evolution of ICS attacks and prospects for future disruptive events. [Online]. Available: https://dragos.com/wp-content/uploads/Evolution-of-ICS-Attacksand-the-Prospects-for-Future-Disruptive-Events-Joseph-Slowik-1.pdf.
- [40] B. Johnson, D. Caban, M. Krotofil, D. Scali, N. Brubaker, and C. Glyer. (June 2019). Threat Research: Attackers Deploy New ICS Attack Framework TRITON and Cause Operational Disruption to

Critical Infrastructure. FIREEYE. [Online]. Available: https://www.fireeye.com/blog/threat-research/2017/12/attackersdeploy-new-ics-attack-framework-triton.html

- [41] J. Weiss. (April 2019). Control system cyberattacks have become more stealthy and dangerous – and less detectable. [Online]. Available: https://www.controlglobal.com/blogs/unfettered
- [42] Dragos. (June 2017). CRASHOVERRIDE: Analysis of the threat to electric grid operations. DRAGOS. [Online]. Available: https://dragos.com/wp-content/uploads/CrashOverride-01.pdf
- [43] SANS ICS. (Aug. 2017). ICS defense use case No.6: Modular ICS malware. [Online]. Available: https://ics.sans.org/media/E-ISAC\_SANS\_Ukraine\_DUC\_6.pdf
- [44] A. Cherepanov. (June 2017). Win32/industroyer: a new threat for industrial control systems. ESET. [Online]. Available: https://www.welivesecurity.com/wp-content/uploads/2017/06/ Win32\_Industroyer.pdf
- [45] Dragos. (December 2017). TRISIS Malware: Analysis of safety system targeted malware. [Online]. Available: https://dragos.com/wp-content/uploads/TRISIS-01.pdf
- [46] TreatSTOP. (February 2016). Security Report: Black Energy. [Online]. Available: https://threatstop.com/sites/default/files/ ThreatSTOP\_BlackEnergy.pdf
- [47] N. Falliere, L. O. Murchu, and E. Chien. (February 2011). W32.stuxnet dossier version 1.4. Symantec. [Online]. Available: https://nsarchive2.gwu.edu/NSAEBB/NSAEBB424/docs/Cyber-044.pdf
- [48] A. Matrosov, E. Rodionov, D. Harley, and J. Malcho, "Stuxnet under the microscope," Rev. 1.31, ESET, 2011.
- [49] E. Byres, A. Ginter, and J. Langill. (February 2011). How stuxnet spreads – A study of infection paths in best practice systems. Tofino Security. [Online]. Available: https://www.tofinosecurity.com/how-stuxnet-spreads
- [50] S. Hong and J. M. Lee, "Direction of security monitoring for substation automation systems," presented at the 5<sup>th</sup> EECSS, August 2019.
- [51] J. Richter, "Chapter 16: Breaking through Process Boundary Walls," in Advanced Windows: The Developer's Guide to the Win32 API for Windows NT 3.5 and Windows 95, 4<sup>th</sup> ed., Redmond, WA, USA: MS Press, 1995.
- [52] M. Shaid, S. Zainudeen, and M. Maarof, "In memory detection of Windows API call hooking technique," in *Proc. Int'l Conf. on Computer, Communications, and Control Technology (I4CT)*, 2015.
- [53] Network System Management: Implementations and Applications of the IEC 62351-7 Standard, EPRI, 2014.
- [54] Power Systems Management and Associated Information Exchange - Data and communications Security - Part 7: Network and System Management (NSM) Data Object Models, IEC TC57 WG15, IEC 62351-7, July 2017.

Copyright © 2020 by the authors. This is an open access article distributed under the Creative Commons Attribution License (<u>CC BY-NC-ND 4.0</u>), which permits use, distribution and reproduction in any medium, provided that the article is properly cited, the use is non-commercial and no modifications or adaptations are made.



Sugwon Hong was born in Incheon, S. Korea. He received the B.S. degree in physics from Seoul National University, Seoul, Korea, in 1979, and the M.S. and Ph.D. degrees in computer science from North Carolina State University, Raleigh, USA, in 1988 and 1992, respectively. His employment experience includes Korea Institute of Science and Technology (KIST) Software Development Center; Korea Energy Economics Institute

(KEEI); SK Innovation Co., Ltd. (formerly Korea Oil Company); Electronic and Telecommunication Research Institute (ETRI). Currently he is a professor in the Department of Computer Engineering, Myongji University, Yongin, S. Korea, where he has been since 1995. His current research interests are cyber security and smart grid.



Jae-Myeong Lee was born in Seoul, S. Korea on September 28, 1992. He received a Bachelor's degree in computer engineering from Myongji University, Korea, in 2018. Then he started his Master's degree program in computer engineering at Myongji University, Korea, from 2018. He is now researching about Machine Learning, Deep Learning, Computer Security, Smart Grid, and SCADA Security, under supervision of Prof.

Sugwon Hong. He was enthusiastic about computer programming from a very young age. In 2009, He was awarded Microsoft Most Valuable Professional (MVP) for Visual Basic by Microsoft, which was the youngest record in Korea.



**Mustafa Altaha** was born on February 7, 1992. He completed his bachelor degree in computer communication at Al Mansour University Colleague, Iraq, in 2014. Then he starts his Master program at Myongji University, Korea, from 2015-2017 at department of information and communication engineering. He is currently in his second year of his Ph.D. in computer engineering department at Myongji University.

Mr. Altaha worked as network operated engineer in Earthlink-Co (biggest Internet service provider in Iraq) from 2014-2015. During his master degree program, he published on OFDM systems, and during his first year as Ph.D. He published an articles on fault tolerance in PTP systems. His current research, is about implementing intrusion detection in SCADA system by using deep learning algorithms.

Mr. Altaha was awarded the first in Iraq in cisco national net-riders competition in network skills in 2014 and, awarded the fifth in Middle East in cisco international net-riders competition in 2014.



**Muhammad Aslam** was born on December 12, 1991. He completed his bachelor degree in electrical engineering at University of Engineering and Technology, Peshawar, Pakistan, in 2013. He completed his Master program at Myongji University, Korea, from 2015-2017 at department of electrical engineering. He is currently in his 3<sup>rd</sup> year of Ph.D. in electrical engineering department at Myongji University. During his Masters, he

worked with Next-Generation Power Technology (NPTC) research center in Myongji University, where he worked on power system protection, power system load flow calculation and Artificial Intelligence (AI). Currently, he is working to apply AI into power system and network security.